

Model 975XL

Reduced Pressure Principle Assembly Backflow Prevention Assembly

Application

Designed for installation on water lines to protect against both backsiphonage and backpressure of contaminated water into the potable water supply. The Model 975XL provides protection where a potential health hazard exists.

Standards Compliance

- ASSE® Listed 1013
- IAPMO® Listed
- CSA® B64.4
- Approved by the Foundation for Cross Connection Control and Hydraulic Research at the University of Southern California

Materials

Main valve body
Access covers
Internals
Cast bronze ASTM B 584
Cast bronze ASTM B 584
Stainless steel, 300 Series
Silicone (FDA approved)
Buna nitrile (FDA approved)

Polymers Noryl™, NSF Listed Springs Stainless steel, 300 series

Features

Sizes: 1/4", 3/8", 1/2"

Maximum working water pressure175 psiMaximum working water temperature180° FThreaded connections (FNPT)ANSI B1.20.1Hydrostatic test pressure350 PSI



Options

(Suffixes can be combined)

with full port QT ball valves (standard)
L - less ball valves, male pipe thread
S - with bronze "Y" type strainer (1/2" only)

TCU - with test cocks up

FT - with integral male 45° flare SAE test fitting
 PF - with Z-Bite[™] push fit connections* (1/2" only)
 PR - with Z-Press[™] press fit connections* (1/2" only)

*Fittings ship in box with valve and must be threaded into valve by hand on site.

valve by harid on sit

Accessories


Air gap (Model AG)


☐ Repair kits (rubber only)

☐ Thermal expansion tank (Mdl. XT) ☐ Soft seated check valve (Model 40XL)

Shock arrester (Model 1250XL)

☐ QT-SET Quick Test Fitting Set





Relief Valve discharge port: 1/4" - 1/2" - 0.38 sq. in.

Dimensions & Weights (do not include pkg.)

МОГ) F I	DIMENSIONS (approximate)													WEIGHT				
SIZ		Д	١	В	}	C	;	D)		Е		F	G	i		H BALL LVES		SS 'ALVES
in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	in.	mm	lbs	kg	lbs.	kg
1/4	8	9 1/2	241	5 3/4	146	1 1/2	38	2 3/4	70	2	51	4	102	N/A	N/A	7	3.2	6	2.7
3/8	10	9 1/2	241	5 3/4	146	1 1/2	38	2 3/4	70	2	51	4	102	N/A	N/A	7	3.2	6	2.7
1/2	15	10	254	5 3/4	146	1 1/2	38	2 3/4	70	2	51	4	102	13 1/2	343	7	3.2	6	2.7


Zurn Industries, LLC | Wilkins

1747 Commerce Way, Paso Robles, CA U.S.A. 93446 Ph. 855-663-9876, Fax 805-238-5766 In Canada | **Zurn Industries Limited**

3544 Nashua Drive, Mississauga, Ontario L4V 1L2 Ph. 905-405-8272, Fax 905-405-1292

Rev. C Date: 10/14 Document No. BF-975XL(SM) Product No. Model 975XL(SM)


MODEL 975XL 1/4", 3/8" & 1/2" (STANDARD & METRIC)



Typical Installation

Local codes shall govern installation requirements. To be installed in accordance with the manufacturers' instructions and the latest edition of the Uniform Plumbing Code. Unless otherwise specified, the assembly shall be mounted at a minimum of 12" (305mm) and a maximum of 30" (762mm) above adequate drains with sufficient side clearance for testing and maintenance. The installation shall be made so that no part of the unit can be submerged or where relief valve discharge could cause damage.

Capacity thru Schedule 40 Pipe											
Pipe size	5 ft/sec	7.5 ft/sec	10 ft/sec	15 ft/sec							
1/8"	1	1	2	3							
1/4"	2	2	3	5							
3/8"	3	4	6	9							
1/2"	5	7	9	14							
3/4"	8	12	17	25							
1"	13	20	27	40							
1 1/4"	23	35	47	70							
1 1/2"	32	48	63	95							
2"	52	78	105	167							



INDOOR INSTALLATION

Specifications

The Reduced Pressure Principle Backflow Preventer shall be ASSE® Listed 1013, rated to 180° F, and supplied with full port ball valves. The main body and access covers shall be low lead bronze (ASTM B 584), the seat ring and all internal polymers shall be NSF® Listed Noryl™ and the seat disc elastomers shall be silicone. The checks shall be oriented at a 45° angle upward and accessible for maintenance without removing the relief valve or the entire device from the line. If installed indoors, the installation shall be supplied with an air gap and "Y" type strainer. The Reduced Pressure Principle Backflow Preventer shall be a ZURN WILKINS Model 975XL.

In Canada | Zurn Industries Limited

³⁵⁴⁴ Nashua Drive, Mississauga, Ontario L4V 1L2 Ph. 905-405-8272, Fax 905-405-1292